

American National Standard

for power systems—

alternating-current electrical systems
and equipment operating at voltages
above 230 kV nominal—
preferred voltage ratings

Approved April 28, 1987

Secretariat: Institute of Electrical and Electronics Engineers, Inc

Page 1 of 2 pages

Foreword

(This Foreword is not part of American National Standard C92.2-1987.)

This standard supersedes ANSI C92.2-1981, Preferred Voltage Ratings for Alternating-Current Electrical Systems and Equipment Operating at Voltages Above 230 kV Nominal. Preferred maximum voltage ratings provide guidance in the development and design of these systems and equipment. Preferred nominal voltage ratings are included to provide consistent standard designations for electrical systems in the extra-high and ultra-high voltage classes.

This standard includes preferred voltage ratings up to and including 1200 kV maximum system voltage, as defined in the standard. Above this value, additional research and development work is needed before standard voltage levels can be specified. It is expected that the next voltage level to be established will be as high as is technically and economically feasible at the time that it is introduced.

ANSI C84.1-1982, American National Standard Voltage Ratings for Electric Power Systems and Equipment (60 Hz), covers standard system voltages up to and including 230 kV nominal system voltage. The discussions in Sections 2 and 3 of ANSI C84.1-1982 contain information that should be helpful in achieving standardization of voltage ratings for alternating-current electrical systems.

1. Scope

This standard provides preferred voltage ratings above 230 kV nominal for alternating-current systems and equipment.

2. Definitions

NOTE: The definitions given in 2.1 through 2.5 for certain terms relating to voltage ratings for alternating-current systems and equipment are intended to clarify the meaning and intent of this standard.

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

ANSI C92.2-1987



2.1 System Voltage. A root-mean-square (rms) phase-to-phase power frequency voltage on a three-phase alternating-current electrical system.

2.2 Maximum System Voltage. The highest rms phase-to-phase voltage that occurs on the system under normal operating conditions, and the highest rms phase-to-phase voltage for which equipment and other system components are designed for satisfactory continuous operation without derating of any kind.

When defining maximum system voltage, voltage transients and temporary overvoltages caused by abnormal system conditions such as faults, load rejection, etc, are excluded. However, voltage transients and temporary overvoltages may affect equipment operating performance and are considered in equipment application.

2.3 Nominal System Voltage. The system voltage by which the system may be designated and to which certain operating characteristics of the system are related.

The nominal voltage of a system is near the voltage level at which the system normally operates. To allow for operating contingencies, sys-

tems generally operate at voltage levels about 5%–10% below the maximum system voltage for which system components are designed.

2.4 Extra-High Voltage (ehv). A maximum system voltage that is greater than 242 kV but less than 1000 kV.

2.5 Ultra-High Voltage (uhv). A maximum system voltage that is equal to or greater than 1000 kV.

NOTE: The classification of ehv and uhv voltages is provided for the purpose of establishing consistency in the use of these terms, reflecting common usage.

3. Preferred System Voltages

The values of preferred system voltages shall be as follows:

Voltage Class	Preferred System Voltage (kV)	
	Nominal	Maximum
ehv	345	362
	500	550
	765	800
uhv	1100	1200

© Copyright 1987 by

The Institute of Electrical and Electronics Engineers, Inc
345 East 47th Street, New York, NY 10017, USA

*No part of this publication may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.*