

Errata to IEEE Standard for the Preparation of Test Procedures for the Thermal Evaluation of Solid Electrical Insulating Materials

Sponsor

Standards Coordinating Committee 4 on Thermal Rating

of the

IEEE Electrical Insulation Society

Correction Sheet

Issued 20 January 2006

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved.
Published 2006. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

Page 15, NOTE 2 to Table B.1—Suggested exposure temperatures and times, should be changed to read as follows:

2—When extending the test program by submitting additional specimens to aging at temperatures below the lower of the originally planned aging temperatures, a temperature interval of 10 °C and a cycle duration of 42 days for TI/RTI determination should be considered.