ITU-T

TELECOMMUNICATION
STANDARDIZATION SECTOR

PROTECTION AGAINST INTERFERENCE

JOINT USE OF POLES FOR ELECTRICITY DISTRIBUTION AND FOR TELECOMMUNICATIONS

ITU-T Recommendation K.5

(Extract from the Blue Book)

OF ITU

NOTES

1	ľ	ΓU-T R	ecommenda	ation I	K.5 v	vas p	oublished	in	Volume	IX	of the	Blue	Book.	This	file is	s an	extrac	et from	ı the
Blue	Book.	While	the present	ation	and 1	layoı	ut of the	tex	t might	be	slightly	diff	erent f	rom t	he Bl	ue E	Book v	ersion	, the
conte	nts of	the file	are identica	l to th	e Blu	ie Bo	ok versio	on a	nd copyi	igh	t condi	tions	remain	unch	anged	(see	e belov	w).	

2	In	this	Recommendation,	the	expression	"Administration"	is	used	for	conciseness	to	indicate	both	a
telecommunication administration and a recognized operating agency.														

© ITU 1988, 1993

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the ITU.

Recommendation K.5

JOINT USE OF POLES FOR ELECTRICITY DISTRIBUTION AND FOR TELECOMMUNICATIONS

(Geneva, 1964)

Administrations that wish to adopt joint use of the same supports for open-wire or aerial cable telecommunication lines and for electricity lines are recommended, when national laws and regulations permit such an arrangement, to take the following general considerations into account:

- 1) There are economic and aesthetic advantages to be derived from the joint use of poles by Administrations and electricity authorities.
- 2) When suitable joint construction methods are used, there is, nevertheless, some increased likelihood of danger by comparison with ordinary construction methods, both to staff working on the telecommunication line and to the telecommunication installation connected thereto. Special training of personnel working on such lines is highly desirable and especially when the electricity line is a high-voltage line.
- 3) The rules given in the *Directives* in connection with danger, disturbance, and staff safety should be complied with (see [1]).
- 4) Special formal agreements are desirable between the Administration and the electricity authority in the case of joint use of poles in order to define responsibilities.
- 5) If joint use is applied on short sections (of the order of 1 km), in most cases a few simple precautions may be enough to ensure that disturbances due to electric and magnetic induction are tolerable.

Reference

[1] CCITT manual Directives concerning the protection of telecommunication lines against harmful effects from electric power and electrified railway lines, Vol. II, ITU. Geneva. 1988.